



## FAYETTEVILLE PUBLIC WORKS COMMISSION

### PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

#### Bid Addendum

**PWC Number:** PWC2425036

**Bid Title:** Storm Support: Emergency Vac Truck Services

**Bid Opening Date and Time:** Tuesday, December 17, 2024

**Addendum Number:** 1

**Addendum Date:** Thursday, December 12, 2024

**Procurement Advisor:** Leticia B. Gilmore

[procurement@faypwc.com](mailto:procurement@faypwc.com)

- 
1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
  
  2. Following are questions received about the solicitation and the SME's answers to the questions.
    - Q1.** Is there a location of solid material that may be removed from the Vac operation?
    - A1.** This operation will be strictly pump and haul. Trucks will pump from lift station wet wells or manholes until full and then transport the sanitary sewer to a designated manhole and discharge same material back into the collection system.
  
    - Q2.** Is there a location to wash out the back of the Vac units or Tankers after the Vac Operation?
    - A2.** Trucks could clean out at the drying beds at the Rockfish Creek WWTP.
  
    - Q3.** Is there a laydown yard or staging area should the Vac crew or tanker need to stage the equipment or sit at for the Stand-by time?
    - A3.** Trucks could stage at the PWC complex or other local designated areas if the drive time for the equipment to arrive at PWC from its home base is more than 2 hours. If the trucks could get to Fayetteville, NC within two hours they could standby at their home base as long as they were committed to PWC should we need to activate them.
  
    - Q4.** Will water be provided for washing out the Vac units and Tankers
    - A4.** Water is available at the Rockfish Creek WWTP if washing out tanks is needed.

---

**Failure to acknowledge receipt of this addendum may result in rejection of the response.**

Check ONE of the following options:

- Bid has not been mailed. Any changes resulting from this addendum are included in our bid response.
- Bid has been mailed. No changes resulted from this addendum.

Bid has been mailed. Changes resulting from this addendum are as follows:

**Execute Addendum:**

**Offeror:** \_\_\_\_\_

**Authorized Signature:** \_\_\_\_\_

**Name and Titled (Typed):** \_\_\_\_\_

**Date:** \_\_\_\_\_